

# 2023 Drinking Water Quality Report

## Consumer Confidence Report

The Safe Drinking Water Act (SDWA) is the federal law that ensures the quality of Americans' drinking water. Under SDWA, the Environmental Protection Agency (EPA) sets standards for drinking water quality and oversees the state, local municipality and water supplier who implements those standards. Amendments to the SDWA require all public water systems with at least 15 service connections or a system that regularly serves at least 25 individuals to publish and distribute a Consumer Confidence Report (CCR) annually.

The CCR increases the availability of information to water customers. Informed and involved customers can be strong allies of their water systems, large and small, as they take action on water issues. Also, an increase in public awareness can give sensitive sub-populations the information that they may need for their protection.

**In order to maintain water quality within your home, it is recommended by the Oakland County Water Resources Commissioner (WRC) that you remove and clean each faucet aerator twice annually and flush stagnant water.** Aerators are the screens that screw into the end of each faucet. In addition, it is also recommended that you annually flush out the water heater and that you regularly maintain any in-home treatment equipment, such as water filters and softeners.

## Special Health Information

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or

other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers.

EPA/Center for Disease Control guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline 800-426-4791.

## Lead Information

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. WRC is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components.

When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to two minutes before using water for drinking or cooking.

If you have a lead service line it is recommended that you run your water for at least five minutes to flush water from both your home plumbing and the lead service line. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline 800-426-4791 or at [www.epa.gov/safewater/lead](http://www.epa.gov/safewater/lead).

## Contaminants

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

**Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

**Inorganic contaminants**, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

**Pesticides and herbicides**, which may come from a variety of sources such as agriculture, storm water runoff, and residential uses.

**Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

**Radioactive contaminants**, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by simply calling the EPA Safe Drinking Water Hotline at 800-426-4791.

## Cross Connection Control Program

Michigan water utilities are required by State law (Michigan Public Act 399) to develop and implement a comprehensive Cross Connection Control Program. The WRC continues to operate and maintain our comprehensive, State approved program for the elimination and prevention of cross-connections in all residential, commercial, medical, industrial and institutional facilities.

Our Cross Connection Control Program is a continuing effort to maintain pure, clean, and safe drinking water for everyone. This is accomplished through inspections, testing, recordkeeping and public education.

For more information about your water system, visit [www.oakgov.com/SoutheastOaklandTwpWater](http://www.oakgov.com/SoutheastOaklandTwpWater)

# Southeast Oakland Township



## 2023 Consumer Confidence Report

This report is designed to inform you about the water quality and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and to protect our water resources. We are committed to ensuring the quality of your water. The Oakland County Water Resources Commissioner (WRC) is pleased to present the Annual Drinking Water Quality Report (CCR) for the year 2023.

The water source is groundwater found in glacial materials. Six wells (one 8-inch and five 12-inch) provide the pumping capacity for this water system (Water System Serial Number [WSSN] 4877). At this time, the Department of Environment, Great Lakes, and Energy (EGLE) has determined the susceptibility for this water system as “moderately low.”

### Your Water Quality

The Southeast Oakland Well Water Supply System is routinely monitored, in accordance with the Safe Drinking Water Act (SDWA), for contaminants in your drinking water. The following tables show the results of our monitoring for the period of January 1 to December 31, 2023. In addition, other test results are shown for the year they were required, since annual testing is not required for some contaminants. The most recent test date for the detected contaminant is listed in the table.

Due to high iron levels, polyphosphate is added to the water as requested in the south pressure district, at the Oakland Valley/Coachlamp well house. Chlorination is required by the EGLE as part of the treatment process.

Unregulated contaminants are those for which the Environmental Protection Agency (EPA) has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted.

The Maximum Contaminant Level (MCL) is the highest level of a contaminant that is allowed in drinking water and is set at a very stringent level. To understand the possible health effects described for many regulated constituents, a person would have to drink two liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

As you can see by the tables, **the system had no violations**. We are proud that your drinking water meets or exceeds all Federal and State requirements. The EPA has determined that your water is safe at the

We are pleased to report that your drinking water is safe and meets Federal and State requirements. If you have questions about this report, or your water utility, please contact your WRC representative, **Kathryn DiCea**, at [wrcwater@oakgov.com](mailto:wrcwater@oakgov.com) or **248-452-9158**. We want our valued customers to be informed about their water utility.

### System Design and Improvements

We work continually to provide high quality water to every tap. In order to maintain a safe and dependable water supply, we may need to make improvements that will benefit all of our customers. These improvements are sometimes reflected as rate structure adjustments. We ask that all our customers help us conserve and protect our water resources, which impact our present lifestyle and our children's future. Please email [wrcwater@oakgov.com](mailto:wrcwater@oakgov.com), call 248-452-9158, or visit our website at [www.oakgov.com/water](http://www.oakgov.com/water) if you have questions.

### Outdoor Water Use

Outdoor water use, primarily sprinkling of lawns, greatly affects water pressure and sizing of water system infrastructure when sprinkling is scheduled during peak demand times. We recommend customers schedule automatic irrigation equipment to water lawns outside of the 5 to 9 a.m. and 5 to 9 p.m. high demand times. Michigan State University recommends light, frequent irrigation applied in the early afternoon <https://bit.ly/3Gc6vaW>. **Water your lawns or set your automatic sprinklers to operate outside of the morning and evening high demand periods to improve your water pressure and decrease costs required for water system expansion.**

levels detected. Data was not included in the tables for a backup well that provided less than 1% of the total water pumped to the distribution system. This data is available upon request.

### Water Quality FAQs

#### Why is my water discolored?

Iron in the water can cause yellow, orange, or red discoloration. Iron is not a health risk but is an aesthetic concern that causes staining and discoloration.

#### Why is my water cloudy?

White/milky cloudiness is typically little air bubbles. To confirm, fill a clear glass with water and set it on your counter. After a short amount of time, it should start to clear from the bottom up.

#### Why does my water smell like chlorine?

Chlorine is a disinfectant that is added to the drinking water. The EPA has determined that levels of chlorine up to four parts per million in drinking water is safe for consumption.

### Hardship Assistance Program

Our office, in partnership with the United Way for Southeastern Michigan, created the Hardship Assistance Program to assist Oakland County households who need help with water and sewer bills but who may not qualify for existing water assistance programs. The Hardship Assistance Program can help eligible Oakland County residents. The program helps residents 1) Pay their current water or sewer bill for up to three months. 2) Eliminate past-due balances. 3) Pay for plumbing repairs. Visit [oakgov.com/wrhardship](http://oakgov.com/wrhardship) to learn more!



# Regulated Contaminants Table

Contaminant	Test Year	Health Goal MCLG	Allowed Level MCL	Highest Detected Level	Range of Detection	Units	Major Sources in Drinking Water	Violation
<b>Inorganic and Volatile Organic Chemicals</b>								
Barium	2021 2022	2	2	0.20	0.17 - 0.20	ppm	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.	No
Fluoride	2023	4	4	0.37	0.10 - 0.37	ppm	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories.	No
<b>Radiological Contaminants</b>								
Combined radium	2021 2023	0	5	0.88	0.45 - 0.88	pCi/L	Erosion of natural deposits.	No
<b>Disinfectant Residuals and Disinfectant By-Products - Monitoring at Customers' Tap</b>								
Total Trihalomethanes (TTHM)	2023	NA	80	9.0	NA	ppb	By-product of drinking water disinfection.	No
Disinfectant (chlorine)	2023	MRDLG 4	MRDL 4	RAA 0.41	0.02 - 0.47	ppm	Water additive to control microbes.	No

# Regulated Contaminants Table Continued

<b>Copper and Lead Monitoring at Customers' Tap</b>								
Contaminant	Test Year	Health Goal MCLG	Action Level AL	90 <sup>th</sup> Percentile Value*	Range of Detection	Units	Major Sources in Drinking Water	Number of Samples Above AL
Copper	Jan-Jun 2023 (N) Jul-Dec 2023 (N) Jul-Dec 2023 (S)	1.3	1.3	0.4 0.5 0.4	0.1 - 0.5 0 - 0.7 0 - 0.9	ppm	Corrosion of household plumbing systems; Erosion of natural deposits.	0
Lead	Jan-Jun 2023 (N) Jul-Dec 2023 (N) Jul-Dec 2023 (S)	0	15	1 0 0	0 - 4 0 - 2 0 - 1	ppb	Lead service lines, corrosion of household plumbing including fittings and fixtures, erosion of natural deposits.	0

\*The 90th percentile value means 90 percent of the homes tested have copper and lead levels below the given 90th percentile value. If the 90th percentile value is above the AL, additional requirements must be met.

North Pressure District (N)      South Pressure District (S)

Per- and polyfluoroalkyl substances (PFAS) were analyzed for in 2023 and were not detected.

The State allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. All of the data is representative of the water quality, but some are more than one year old.

# Unregulated Contaminants Table

Contaminant	Test Year	MCLG	MCL	Average Level	Range of Detection	Units	Major Sources in Drinking Water
Calcium	2023	NA	NA	94	83 - 100	ppm	Naturally occurring due to geological processes.
Chloride	2023	NA	NA	37	30 - 41	ppm	
Hardness	2023	NA	NA	353	314 - 373	ppm	
Iron	2023	NA	NA	1.5	1.0 - 1.9	ppm	
Magnesium	2023	NA	NA	29	26 - 30	ppm	
Sodium	2023	NA	NA	16	14 - 18	ppm	
Sulfate	2023	NA	NA	35	0 - 54	ppm	

## NOTICE TO NON-RESIDENTIAL CUSTOMERS

Federal Regulations require that as the billing customer, it is your responsibility to ensure that all water consumers at your facility (whether business, educational institute, apartments, etc.) have access to the report. Please post this CCR in a visible area. Copies are available for your distribution by contacting the WRC office at [wrcwater@oakgov.com](mailto:wrcwater@oakgov.com) or 248-452-9158.

## Important Definitions

**Action Level (AL)** - The concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow.

**Haloacetic Acids (HAA5)** - HAA5 is the total of bromoacetic, chloroacetic, dibromoacetic, dichloroacetic, and trichloroacetic acids. Compliance is based on the total.

**Maximum Contaminant Level (MCL)** - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - The level of contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Not Applicable (NA)**

**Not detected (ND)** - Not detectable at testing limit.

**Parts Per Billion (ppb)** - The ppb is equivalent to microgram per liter. A microgram = 1/1000 milligram. A ppb is equivalent to one penny in \$10,000,000.

**Parts Per Million (ppm)** - The ppm is equivalent to milligram per liter. A milligram = 1/1000 gram. A ppm is equivalent to one penny in \$10,000.

**pCi/L** - picocuries per liter (a measure of radioactivity)

**Running Annual Average (RAA)** - The average of analytical results for all samples during the previous four quarters.

**Total Trihalomethanes (TTHM)** - The sum of chloroform, bromodichloromethane, dibromochloromethane and bromoform. Compliance is based on the total.

# MAINTAINING QUALITY DRINKING WATER IN YOUR HOME


## A Shared Responsibility

Maintaining drinking water quality is a shared responsibility between the water supplier and the resident.

## We're Committed to...


- Protecting public health and wellness.
- Delivering the same clean, high-quality water we've always delivered.
- Providing greater public education.

**In order to maintain or improve water quality at home, there are a few things you should remember to do on a regular basis:**



### Remove and Clean Your Aerator Every 6 Months.

The aerator is that screen on the end of your faucet, and it's important to remove it and clean it every six months.



*Also, if you have any plumbing work done, remove and clean the aerators on every faucet to get rid of particles that build up.*

### Flush Water that Has Been Sitting in Your Pipes.

Overnight, water sits stagnant in your pipes. And the longer it sits there, the more metal it may contain. So, flush your pipes by running the cold water for several minutes before you use it.



### Replace Faucets, Fittings or Valves From Before 2014.

Even if marked 'lead-free,' faucets, fittings and valves sold before 2014 may contain higher levels of lead than the current tolerance of 0.25%. It might be time to upgrade.



### Drink and Cook With Cold Water

Only use cold water for drinking or cooking. Hot water can sit for long periods of time in a hot water heater and could contain dissolved metals.

**Purely Resourceful**

[www.oakgov.com/water](http://www.oakgov.com/water)